

**INSTITUT IMS AD
BEOGRAD**

Institut za ispitivanje materijala a.d. Beograd- *Institute for Materials Testing a.d. Beograd*
Central laboratory for material testing
Laboratory for thermal technology and fire protection
Belgrade, 43 Bulevar vojvode Mišića Str.
phone: (011) 26 50 322 fax: (011) 3692 772, 3692 782 www.institutims.rs

CLASSIFICATION REPORT

GFT-8471/23-CLS

Subject of examination: Fire classification of contact facade systems made of mineral wool based on the results of reaction to fire in accordance with the standard **SRPS EN 13501-1:2019+A1**, type: **Bekatherm Prestige**, manufacturer: **Banja Komerc Bekament d.o.o.**

Customer: **Banja Komerc Bekament d.o.o.**
132 Kralja Petra Prvog Str.
34304 Aranđelovac, Banja

Request/Offer/Contract: Offer no. 41-17704 dated on 08.12.2022.

Content: The report contains 6 (six) pages.

Report approved by: Laboratory for thermal technology and fire protection.

Head of the laboratory
Dragiša Ivanišević, BSc in Mech.Engineering
(for Snežana Ilić), signed, sealed

Belgrade, February 03, 2023.

4. CLASSIFICATION AND FIELD OF PRODUCT APPLICATION

4.1 Classification standard

The classification of the product is carried out in accordance with the standard **SRPS EN 13501- 1:2019**.

4.2 Fire classification

The mineral wool contact facade system, type: **Bekatherm Prestige**, can be classified based on the results of the reaction to fire as:

Classification based on the results of fire reaction tests:

A2 s1 do

5. LIMITATIONS

The classification report does not represent product certification. This report confirms the performance of the material based on the results of the fire reaction test.

The validity period of the classification report is 5 years.

Belgrade, February 03, 2023.

Izveštaj uradio/la:

Đorđe Simić, MSc.of Mech.Eng.
(signature illegible)

Test Manager:

Dragiša Ivanišević, BSc in Mech.Eng. (for Snežana Ilić)

The end of report